

ENGLISH VERSION OF THE OFFICIAL FRENCH PROCÈS-VERBAL N° EFR-24-005656

Only the original French edition of this procès-verbal is authentic.
Seule l'édition originale en français du présent procès-verbal fait foi.

The French PROCES VERBAL is valid for 5 years starting on February 25th, 2025

Applicant	TECNOVENTIL SPA Via degli Imprenditori 4 26016 SPINO D'ADDA (CR) Italie
Sample reference	SERIES S - SYNTHETIC FILTRATION MEDIA
Brief description provided by the applicant	Non-woven polyester filter media, surface flame-retardant
Mass per unit area determined by the laboratory	250 g/ m ² ± 10%
Thickness measured by the laboratory	0,67 mm ± 10%
Colour	White
End-use condition	Air filtration

Standard of tests:

- **NF P 92-507 (2004)** - Building - Interior fitting materials - Classification according to their reaction to fire
- **NF P 92-503 (1995)** - Reaction to fire tests - Electrical burner test used for flexible materials
- **NF P 92-504 (1995)** - Reaction to fire tests - Flame persistence test and speed of the spread of flame
- **NF P 92-505 (1995)** - Reaction to fire tests - Test used for thermal melting materials - Dripping test

Classification obtained in the official Procès Verbal:

M1

Valid one year from its implementation date

Valid for any application for which the product is not subjected to the CE marking.

Durability of the classification (NFP 92-512: 1986): Valid one year from its implementation date

Taking into account the criteria resulting from the tests described in the test report n°EFR-24-005656-BE from February 27th, 2025.

This test report only demonstrates the characteristics of the test sample and does not prejudice the characteristics of similar products. It does not provide a certification of products within the Article L.433-3 of the Consumer Code and the Law of June 3rd, 1994.

Efectis France is approved for fire reaction tests according to the Decree of December 29th, 2016 amending the Decree of February 5th, 1959.

Saint-Aubin, on February 27th, 2025